

Grid connection test

/Prove e verifiche di connessione in rete

Test Report

/ Rapporto di prova

Test report no. **INV01 17WC073001**
/Rapporto di prova n°.

Test product <i>/Prodotto in prova</i>	Hybrid Converter – Interface accumulation unit for Photovoltaic inverter
Customer <i>/Cliente</i>	P800 srl Via Valdilocchi, 6/F 19126 La Spezia
Type-model <i>/Modello</i>	Solar Eclipse – Firmware Release: 1.7.5

The sample of the described product has successfully passed the tests listed in the test report file and fulfills the product requirements of the standard:

/Il campione del prodotto descritto ha superato con successo i test elencati nel rapporto di prova e soddisfa i requisiti della norma di prodotto:

Standards /Norme:

CEI 0-21:2016

Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti BT delle imprese distributrici di energia elettrica

/Reference technical rules for the connection of active and passive users to the LV electrical Utilities.

- **Allegato B bis /Annex B bis Functional Test /Test Funzionali**

Tribano, 22/06/2017

The laboratory Manager
Ing. Roberto Bolzonaro

Firmato digitalmente da
ROBERTO BOLZONARO


